



- NOTES
1. POSTS:
2130 X 100 Ø X 3mm MILD STEEL TUBING WITH STEEL CAP AND 230 X 230 X 3mm BASE PLATE, FULLY GALVANIZED (SANS 121/ISO 1461) (WITHOUT HOLES FOR WIRES).
 2. STAYS:
2130 X 60 Ø X 3mm MILD STEEL TUBING WITH 230 X 230 X 3mm BASE PLATE, FULLY GALVANIZED (SANS 121/ISO1461).
 3. STANDARDS:
1850 X 2,5 kg/m "Y" SECTION COMPLETE WITH HOLES AT 50mm CENTRES. FULLY GALVANIZED (SANS 121/ISO1461) IF WITHIN 25 km FROM THE COAST.
 4. DROPPERS:
1200 X 0,56mm kg/m RIDGEBACK PATTERN (SANS 121/ISO1461), FULLY GALVANIZED IF WITHIN 25km FROM THE COAST.
 5. CROSS BRACE SUPPORT :
2400 X 60 Ø X 3mm MILD STEEL TUBING BENT AND FLATTENED AS SHOWN, FULLY GALVANIZED (SANS 121/ISO 1461). ENDS PRESSED FLAT TO ± 8mm.
 6. GOVERNMENT PATTERN FARM GATE :
MANUFACTURED FROM 42.9 Ø x 2.6mm STEEL TUBING WITH HINGES, WASHERS, BOLTS AND LOCKING CHAIN ATTACHED TO GATE (COMPLYING WITH CKS 146).
ALL FULLY GALVANIZED (SANS 121/ISO 1461).
 7. BARBED WIRE:
3,2 X 2,5mm OVAL HIGH TENSILE GRADE SINGLE STRAND (SANS 675), FULLY GALVANISED.
 8. SMOOTH WIRE:
3,0mm Ø HIGH TENSILE GRADE (SANS 675) FULLY GALVANIZED.
 9. TYING WIRE:
2,5mm Ø MILD STEEL (SANS 675), FULLY GALVANIZED FOR TYING TO STANDARDS AND DROPPERS.
 10. STRAINING WIRE :
4mm Ø MILD STEEL (SANS 675), FULLY GALVANIZED . (4 STRANDS, DOUBLED AND TWISTED TO TAKE STRAIN).
 11. BOLTS FOR STAYS:
12mm Ø MILD STEEL , INCLUDING NUTS AND WASHERS, FULLY GALVANIZED.
 12. MAXIMUM SPACING OF:
STRAINING POSTS 180m c/c
STANDARDS 15m c/c
DROPPERS 3m c/c
 13. ALL WIRES TO BE ERECTED ON THE ROAD SIDE OF THE FENCE UNLESS OTHERWISE INSTRUCTED
 14. MINIMUM CONCRETE STRENGTH OF FOOTINGS 20 MPa AT 28 DAYS.